



कार्यालय नगर निगम ग्रेटर, जयपुर

क्रमांक :-

(पण्डित दीनदयाल उपाध्याय भवन, लालफोटी, टोंक रोड जयपुर-302015, राजस्थान)
एफ.31()मु.स्वा.अधि./ननिज/2025/109

दिनांक :- 12-6-25

SAFE DRINKING WATER AND SANITARY CONDITIONS CERTIFICATE

It is certified that an inspection team headed by **Dr. Rashmi Kankaria**, Chief Health Officer from Nagar Nigam Greater, Jaipur inspected the **SUBODH PUBLIC SCHOOL**, Near Airport Sanganer, Jaipur on 02-05-2025 and on the basis of the Water Test Report (Attached) bearing no 4592 dated 17-03-2025 certified that the **SUBODH PUBLIC SCHOOL**, has safe drinking water facilities for the students and members of staff of the institution, School is maintaining the hygienic sanitation condition in the building & the campus as per the norms prescribed by the Central/State/U.T.Govt.

The Certificate is valid upto 31 March. 2026.

(Dr. Rashmi Kankaria)
Chief Health Officer
Nagar Nigam Greater Jaipur

To,

The Principal,

SUBODH PUBLIC SCHOOL,
Near Airport Sanganer, Jaipur

Signature valid

Digitally signed by Rashmi Kankaria
Designation: Chief Health Officer
Date: 2025.06.12 17:34:34 IST
Reason: Approved



OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, CENTRAL LABORATORY
Gandhi Nagar (Near Reserve Bank Quarters), Rajasthan, Jaipur - 302 015
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

No: Lab/Bact/2024-25/ 4594

Dated: 17/3/2025


To
Subodh Public School
Near Air Port Sanganer
Jaipur

Reference : - Your Application on dated 06/03/2025
GRN NO. : -101747289 Paid on Date 06/03/2025

Distt: Jaipur
Tehsil: Jaipur

Sample No.	Date of Collection	Date of Examination	Area	Particulars of Samples	Coliform Organisms MPN/100 ml	E-Coli Organism (MPN)	Remarks (Satisfactory/ Unsatisfactory)
P:113 3673	6/3/2025	6/3/2025	Jaipur	TW Water Subodh Public School, Sanganer	Nil	Nil	Satisfactory

Remark-1-Not Valid for water quality Legal cases
2- The Sample was not collected by this laboratory



Superintending Chemist(HM & Jaipur City)
PHED, Laboratory, Jaipur

No: Lab/Bact/2024-25/

Dated:

Copy to:

1. The Chief Chemist, PHED, Rajasthan, Jaipur


Superintending Chemist (HM & Jaipur City)
PHED, Laboratory, Jaipur

OFFICE OF THE CHIEF CHEMIST

PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2024-2025/ 4592

Date: 17/3/2025

To,
Principal,
Subodh Public School,
Near Airport Sanganer,
Jaipur.

Date of Receipt-06-03-2025

The sample was not collected
by the laboratory

Sample for water
analysis is not available

Particulars			Boring Water
	value as per I.S.:10500/2012		
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			06.03.2025
Lab. Sample No.			P-176
1. pH	6.5-8.5	6.5-8.5	7.56
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo3) mg/l	200	600	260
6. Total Hardness (as CaCo3) mg/l	200	600	200
7. Calcium (as Ca) mg/l	75	200	40
8. Magnesium (as Mg) mg/l	30	100	24
9. Chloride (as Cl-) mg/l	250	1000	120
10. Nitrates (as NO3-) mg/l	45	45	40
11.Sulphate(as So4-2)mg/l	200	400	20
12. Total Dissolved Solids mg/l	500	2000	560
13.Fluoride mg/l	1.00	1.5	0.24
14.Iron mg/l	1.0	No Relaxation	Nil
15.Arsenic mg/l	0.01	No Relaxation	Nil

Remark- 1. All chemical parameters except pH are in mg/l
2. Tested Results Relate only to The Samples send by you.

Sent
Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur

No: Lab/ Sup.Chem. (HM) / Jaipur (City) /2024-2025/

Date:

Copy to:- 1.The Chief Chemist, PHED Raj. Jaipur

Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur